

*These piping diagrams are examples for illustrative purposes only. They are not designed to be used as a piping schematic.*

- \*Max. 4 pipe diameters between tees
- \*External Low Water Cut-Off if required by local code
- \*Tempering Valve May be Required – Consult Local Codes
- \*Must leave at least 15” of straight pipe on either side of closely spaced tees

**Primary Piping Sizes:**

- PCH 18/BHK – 1” Copper
- PCH 34/BHK – 1 ¼” Copper
- PCH 50/BHK – 1 ½” Copper
- PCI 18/8HK – 1” Copper
- PCC 34HK – 1 ¼” Copper

